

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7165-0028:181

Page 1 of 2

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Notifier, One Fire-Lite Place, Northford CT 06472-1001  
Contact: Larry Flood (203) 484-1200 FAX (203) 484-7309

**DESIGN:** Models AFP-300 and AFP-400 fire alarm control units. Automatic, manual, coded, non-coded, local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU). Also suitable for waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

CPU-300/400	CPU Board
MPS-400	Power Supply Board
CAB Series, CAB-400AA*	Enclosure
4XTM	Transmitter Module
BB-17/-55	Battery box
MMX-1/-101	Monitor Module
ISO-X	Isolator Module
N-ELR/A2143-00	EOL Resistor
CMX-1	Control Module
XPP-1/XPM-8/XPR-8/XPC-8	XP Transponder
XPDP	Transponder Dress Panel
CRT-2	Terminal with Keyboard
ARM-4	Auxiliary Relay Module
AVPS-24	Audio/Visual Power Supply
CRE-4	Control Relay Expander
CRM-4	Control Relay Module
FCPS-24	Field Charger Power Supply
FKS-2400	Modem
ICE-4/ICM-4	Indicating Control Expander
NIB-96	Network Interface Board
NR45-24	Notifier Remote Battery Charger
RPT-485F/-W/-WF	EIA-485 Repeater
UZY-256	Universal Zone Coder
MP-1/DP-1/-3/-400AA	Dress Panel
BM-1	Blank Module
TR-500	Trim Ring
ICM-4	Indicating Control Module
NAM-232	Network Adapter Module
MPS-24A/-24B	Main Power Supply
ABS-4D	Annunciator Backbox
ADP-4	Dress Panel
INA	Remote Annunciator

Refer to CSFM Listing No. 7170-0028:182 for additional optional accessories.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. Units can also generate the temporal code pattern as required per NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, 8<sup>th</sup> Edition Standard.

**NOTE:** For **Fire Alarm Verification Feature** (Delay of fire alarm), the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

\*Rev. 11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*